



- KEY NOTES**
(NOTE: THESE NOTES MAY NOT APPEAR ON ALL SHEETS)
- 1 PROVIDE FATC, 6X6X4, NEMA 3R PULLBOX W/TERMINAL BLOCKS, RISE CONDUIT UP & LB INTO ACCESSIBLE CEILING SPACE W/FIRE ALARM SYSTEM CONDUCTORS.
 - 2 PROVIDE 1" C. SLEEVE BETWEEN RELOS WITH PLASTIC BUSHINGS AT BOTH ENDS. REFER TO DETAIL #5 ON SHEET E300.
 - 3 SET SPEAKER FOR 1/4W.
 - 4 SET SPEAKER FOR 1/2W.
 - 5 SET SPEAKER FOR 1W.
 - 6 SET SPEAKER FOR 2W.
 - 7 EXISTING FIRE ALARM PULLBOX.
 - 8 PROVIDE 1-1/4" C. W/(3) WEST PENN. #AQC294, & (1) WEST PENN. #AQC227. (2Z,1A,1V)
 - 9 PROVIDE 2" C. W/(2) WEST PENN. #AQC294, & (1) WEST PENN. #AQC227. (1Z,1A,1V)
 - 10 NOT USED.
 - 11 PROVIDE 1-1/4" C. W/(3) WEST PENN. #AQC294 & (1) 8 STRAND FIBER OPTICAL AUDIO LOOP TO RSD), SUPERIOR ESSEX, # W3008601. (2Z, 2A, D.A.L.)
 - 12 PROVIDE 10"x11" TRAFFIC RATED PULLBOX W/STEEL CHECKER PLATE COVER ENGRAVED W/FIRE ALARM #8107RBOX, WITH #81017-514H COVER, BY CHRISTY CONCRETE.

NOTE: ATTIC SPACE IS BEAM CONSTRUCTION. 6" DEEP PURLINS @48" O.C. RUNNING PARALLEL WITH ROOF RIDGE. HEAT DETECTOR SPACING NO MORE THAN 2/3 LISTED SPACING AT RIGHT ANGLES TO PURLINS.

NO WORK

AGENCY INFORMATION:
 AGENCY TRACKING NO. 63321-356
 FILE NO. 15-6
 IDENTIFICATION STAMP
 DIV. OF THE STATE ARCHITECT
 OFFICE OF REGULATION SERVICES
03-120240
 AG. FLS. SPS.
 DATE: JAN 02 2020

SEAL

COPYRIGHT:
 Any reproduction or distribution for any purpose other than authorized by IBI Group is forbidden.

COPYRIGHT 2019 IBI GROUP

REVISIONS			
NO.	DATE SUBMITTED	DATE APPROVED	DESCRIPTION

CONSULTANT
FERRANTI ENGINEERING
 CONSULTING ELECTRICAL ENGINEERS
 1211 MARICOPA HWY,
 SUITE 250
 OJAI, CA 93023
 (805) 705-4772
 DALEFERRANTI@LIVE.COM

PRIME CONSULTANT
IBI ARCHITECTURE PLANNING
 San Luis Obispo
 4119 Broad Street, Suite 210
 San Luis Obispo, CA 93401
 805.546.0433
 fax: 805.546.0504
 ibigroup.com

BAKERSFIELD CITY SCHOOL DISTRICT

BESSIE OWENS E.S. KINDERGARTEN MODULAR BUILDINGS
 815 POTOMAC AVE, BAKERSFIELD, CA 93307

OPSC or OSHPD PROJ. NO.:	N/A
PROJECT NO.:	118932
DRAWN BY:	V.Z.
CHK'D BY:	D.F.
ISSUE DATE:	10/29/2019
SHEET TITLE:	FIRE ALARM PLAN KINDERGARTEN MODULAR BUILDINGS
SHEET NUMBER:	E301

CONSTRUCTION DOCUMENTS