


1" = 40'-0"  
 1" = 30'-0"  
 1" = 20'-0"  
 1" = 1'-0"  
 1/8" = 1'-0"  
 1/4" = 1'-0"



### FIRE ALARM SEQUENCE OF OPERATIONS

MANUAL PULL STATION	SMOKE DETECTORS:	HEAT DETECTORS:	DUCT DETECTOR:	WIRING CONDITIONS:
ALL (EXCEPT LISTED BELOW)	WIRE-TO-WIRE SHORT			
PRIMARY FLOOR LOBBY	PRIMARY FLOOR LOBBY	ELEVATOR MACHINE ROOM	FIRE SPRINKLER WATERFLOW SWITCH	SINGLE OPEN
ALL OTHER LOBBIES	ALL OTHER LOBBIES	ELEVATOR SHAFT	FIRE SPRINKLER TAMPER SWITCH	SINGLE GROUND
ELEVATOR MACHINE ROOM	ELEVATOR MACHINE ROOM		POST INDICATOR VALVE	NOTIFICATION APPLIANCE CIRCUIT (NAC)-
ELEVATOR SHAFT	ELEVATOR SHAFT			WIRE-TO-WIRE SHORT
				SINGLE OPEN
				SINGLE GROUND
				LOSS OF 120VAC POWER
				SIGNAL SILENCE
				RESET FACP

NOTE: SOME SEQUENCE OF OPERATIONS SHOWN MAY NOT APPLY

### FA CABLE SCHEDULE

TYPE	DESCRIPTION
A	INITIATING CIRCUIT CABLE 2#16 AWG SOLID COPPER PVC JACKET POWER LIMITED FPLR CABLE, FOR INDOOR AND OUTDOOR VIA MIN. 3/4" CONDUIT INSTALLATION
B	NAC SIGNAL CIRCUIT CABLE 2#12 AWG SOLID COPPER PVC JACKET POWER LIMITED FPLR CABLE, AND SPEAKER CIRCUIT CABLE 2#16 SHIELDED COPPER PVC JACKET POWER LIMITED FPLR CABLE FOR INDOOR AND OUTDOOR VIA MIN. 3/4" CONDUIT INSTALLATION

### BATTERY POWER CALCULATIONS

#### 1 EXISTING NAC SIGNAL & VOICE BOOSTER PANEL

DEVICE	NO. OF DEVICE	CURRENT PER DEVICE STANDBY	ALARM	STANDBY CURRENT	ALARM CURRENT
EXISTING OUTDOOR SPEAKER	1	0.050A	0.120A	0.120A	0.050A
NEW OUTDOOR SPEAKER	1	0.050A	0.120A	0.120A	0.050A
NEW AUDIO/VISUAL 15cd	3	0.093A	0.279A	0.279A	0.093A
EXISTING AUDIO/VISUAL 75cd	3	0.157A	0.471A	0.471A	0.157A
NEW AUDIO/VISUAL 75cd	1	0.157A	0.471A	0.471A	0.157A
EXISTING 1/4 W SPEAKER	3	0.010A	0.030A	0.030A	0.010A
NEW 1/4 W SPEAKER	4	0.010A	0.040A	0.040A	0.010A
<b>SUB-TOTAL</b>				1.200A	10.077A

24 HOUR STANDBY CURRENT: 2.880AH  
 5 MINUTE ALARM CURRENT (0.083 HR): 2.519AH  
 SUBTOTAL: 5.399AH

20% SAFETY FACTOR: 1.080AH  
 TOTAL AMPS-HRS REQUIRED: 6.479AH

REPLACE EXISTING BATTERY WITH (2) NEW 12AH BATTERY

### BATTERY POWER CALCULATIONS

#### 2 EXISTING FIRE ALARM CONTROL PANEL (FACP) IN EXISTING ADMIN BUILDING

DEVICE	NO. OF DEVICE	CURRENT PER DEVICE STANDBY	ALARM	STANDBY CURRENT	LED CURRENT
EXISTING ESTIMATE LOAD	1	0.25A	4.5A	0.25A	4.5A
NEW SMOKE DETECTOR	5	0.0003A	0.0065A	0.0015A	0.0325A
NEW HEAT DETECTOR	4	0.0003A	0.0065A	0.0012A	0.026A
<b>SUB-TOTAL</b>				0.2527A	4.559A

24 HOUR STANDBY CURRENT: 6.065AH  
 15 MINUTE LED CURRENT (0.25 HR): 1.140AH  
 SUBTOTAL: 7.205AH

20% SAFETY FACTOR: 1.441AH  
 TOTAL NEW AMPS-HRS REQUIRED: 8.646AH

REPLACE EXISTING BATTERIES WITH (2) NEW 18AH BATTERIES

### BATTERY POWER CALCULATIONS

#### 3 EXISTING AUDIO AMPLIFIER NOTIFIER#VVC IN EXISTING ADMIN BUILDING

DEVICE	NO. OF DEVICE	CURRENT PER DEVICE STANDBY	ALARM	STANDBY CURRENT	ALARM CURRENT
EXISTING UNIT	1	0.130A	1.000A	0.130A	1.000A
(E) BOOSTER PNL	1	0.130A	1.000A	0.130A	1.000A
<b>SUB-TOTAL</b>				0.260A	2.000A

24 HOUR STANDBY CURRENT: 6.240AH  
 15 MINUTE ALARM CURRENT (0.25 HR): 0.500AH  
 SUBTOTAL: 6.740AH

20% SAFETY FACTOR: 1.348AH  
 TOTAL NEW AMPS-HRS REQUIRED: 8.088AH

REPLACE EXISTING BATTERY WITH (2) NEW 12AH BATTERIES

### VOLTAGE DROP CALCULATION

WORST CASE VOLTAGE DROP AT THE LAST DEVICE

VD = VOLTAGE DROP  
 I = TOTAL LOAD  
 K = 21.6  
 L = DISTANCE TO THE LOAD  
 CM = CIRCULAR MILLS (CROSS SECTION OF 12 AWG = 6530)  
 VD = VOLTAGE (24Vdc)  
 VD =  $K \cdot I \cdot L \cdot CM$

SIGNAL CKT	AMPERES	APPROX LENGTH	RESISTIVITY OHM	WIRE AWG	AREA CM	VOLTS DROPPED	% VOLTS DROP
CKT#B SIREN	0.486A	280'	21.6	12	6530	0.450V	1.9%
CKT#B SPEAKER	0.050A	280'	21.6	12	6530	0.046V	0.2%

### F.A. MONITORING NOTES

- THE AUTOMATIC FIRE ALARM SYSTEMS SHALL TRANSMIT THE ALARM, SUPERVISORY AND TROUBLE SIGNALS TO AN APPROVED SUPERVISING STATION AS REQUIRED BY NFPA 72 AND AMENDED EITHER UJFF OR UJUS BY UNDERWRITERS OF FACTORY MUTUAL RESEARCH APPROVAL STANDARD 3011. SUPERVISION OF SYSTEM AND LEASED TELEPHONE LINES SHALL BE ARRANGED BY OWNER.

### COMPLETE AUTOMATIC FIRE ALARM PLAN SUBMITTAL

- THE FIRE ALARM SYSTEM SHOWN ON THESE PLANS HAS BEEN SUBMITTED AND APPROVED BY DIVISION OF THE STATE ARCHITECT. ANY SUBSTITUTION OF THE FIRE ALARM SYSTEM SHALL BE RESUBMITTED TO THE ARCHITECT FOR REVIEW AND APPROVAL. THE CONTRACTOR SHALL PAY ANY ADDITIONAL FEES THAT ARE INCURRED DUE TO THIS SUBSTITUTION.
- THE AUTOMATIC FIRE ALARM SYSTEM SHALL COVER ALL ROOMS AND AREAS AND UPON ACTIVATION OF AN INITIATING DEVICE ALERT ALL OCCUPANTS AND TRANSMIT THE ALARM, SUPERVISORY, AND TROUBLE SIGNALS TO AN APPROVED SUPERVISING STATION. (EXCEPTION: SMOKE DETECTORS ARE NOT REQUIRED IN NON-ACCESSIBLE AREAS AS DEFINED IN EMERGENCY EXPRESS TERMS OF PROPOSED S.F.M. AMENDMENTS TO 2016 C.F.C. SECTION 210 (C.F.C. SECTIONS 1006.2.4.2.2.1.1 AND 1006.2.4.2.2.1.5)

### SHEET NOTES

- EXISTING FIRE ALARM SIGNAL AND AUDIO BOOSTER PANEL AND CONNECT TO (E) FACP PER RISER DIAGRAM. (E) 110V POWER CONNECTION AND DEDICATED CIRCUIT FROM PANEL A-12. PROVIDE FIRE ZONE MAP. MEASURE ACTUAL LOAD CURRENT AND VOLTAGE DROP FOR EACH NAC SIGNAL CIRCUIT, AND STANDBY CURRENT AND ALARM CURRENT. SEND THE REPORT TO OWNER AND ENGINEER FOR REVIEW, AND PLASTIC LAMINATED ONE COPY INSIDE CABINET DOOR. SEE FA RISER DIAGRAM FOR DETAILS.
- LOCATE HEAT DETECTOR IN ATTIC AND SURFACE MOUNT ON THE BOTTOM OF RAFTER. DETECTOR COVERAGE WILL BE GENERAL 50% ACROSS THE RAFTER. FIELD VERIFY LOCATION WITH GENERAL CONTRACTOR AND PROVIDE ATTIC HEAT DETECTOR IN EACH BAY OF STRUCTURAL.
- INTERCEPT EXISTING INITIATING CIRCUIT AND EXTEND TO NEW FA DEVICES PER PLANS.
- NEW WP FLEX 3/4" CONDUIT AND FA WIRING BETWEEN BUILDING ATTIC SPACE. SEE DETAIL 4/E-4.

### F.A SYSTEM SCOPE OF WORK

- PROVIDE AUTOMATIC FIRE ALARM SYSTEM WITH VOICE EVACUATION SPEAKERS FOR THE NEW CLASSROOM BUILDINGS PER PLANS.
- EXISTING FACP IS 24VDC ADDRESSABLE, AND CLASS B WIRING SYSTEM. AND WITH OFF SITE MONITORING SERVICE VIA AUTO DUAL LINE DIALER AND TELEPHONE LINES.
- DURING THE FINAL TESTING, MEASURE ALL FIRE ALARM CURRENTS, VOLTAGE DROP FOR EACH SIGNAL CIRCUIT. SEND OWNER AND ENGINEER ONE COPY RECORD FOR REVIEW, AND PLASTIC LAMINATED ONE COPY INSIDE FACP CABINET DOOR.
- COMPLETE FIRE ALARM DRAWING SUBMITTAL IS PROVIDED.

### FIRE ALARM NOTES



- APPLICABLE STANDARD 2016 NFPA 72
- INSTALLATION OF THE SYSTEMS SHALL NOT BE STARTED UNTIL DETAILED DESIGN DOCUMENTS AND SPECIFICATION, INCLUDING STATE FIRE MARSHAL LISTING NUMBERS FOR EACH COMPONENT OF THE SYSTEM HAS BEEN APPROVED BY DSA.
- COMPLETION OF THE INSTALLATION OF THE SYSTEMS, A SATISFACTORY TEST OF THE ENTIRE SYSTEM SHALL BE MADE IN THE PRESENCE OF A DSA PROJECT INSPECTOR.
- A STAMPED SET OF APPROVED FIRE ALARM DESIGN DOCUMENTS SHALL BE ON THE JOB SITE AND USED FOR INSTALLATION.
- ANY DISCREPANCIES BETWEEN THE DRAWINGS AND THE CODE OR ANY DISCREPANCIES SHALL BE BROUGHT TO THE ATTENTION OF DSA AND THE ARCHITECT/ENGINEER OF THE PROJECT.
- DSA, ARCHITECT/ENGINEER AND OWNER SHALL BE NOTIFIED A MINIMUM OF 48 HOURS PRIOR TO THE FINAL INSPECTION AND /OR TESTING.
- PENETRATIONS THROUGH RATED ASSEMBLIES, REQUIRING OPENING PROTECTION SHALL BE PROVIDED WITH A PENETRATION FIRE STOP SYSTEM AS IDENTIFIED IN CBC CHAPTER 7, UL OR OTHER LAB TESTING CRITERIA. APPROVED TYPE OF MATERIALS SHALL BE IDENTIFIED WITHIN THE SPECIFICATION WITHIN THE FIRE ALARM SECTION.
- WALL MOUNTED VISUAL NOTIFICATION DEVICES SHALL HAVE THEIR BOTTOMS MOUNTED AT 80" MINIMUM AND 96" MAXIMUM FROM FINISHED FLOOR.
- WALL MOUNTED AUDIBLE NOTIFICATION DEVICES SHALL HAVE THEIR TOPS MOUNTED AT 90" MINIMUM AND 100" MAXIMUM FROM FINISHED FLOOR AND NO CLOSER THAN 6" TO A HORIZONTAL STRUCTURE.
- AUDIBLE DEVICES SHALL PROVIDE A SOUND PRESSURE LEVEL OF 15 DEGBELS (Db) ABOVE THE AVERAGE AMBIENT SOUND LEVEL OR 5 DBA ABOVE THE MAXIMUM SOUND LEVEL HAVING A DURATION OF AT LEAST 60 SECONDS, WHICHEVER IS GREATER, IN EVERY OCCUPIABLE SPACE WITHIN THE BUILDING.
- AUDIBLE DEVICES SHALL BE SYNCHRONIZED TEMPORAL CODE 3 PATTERN.
- THE CONTRACTOR SHALL ADJUST/INSTALL ALL DEVICES TO MAXIMIZE PERFORMANCE AND TO MINIMIZE FALSE ALARMS.
- VISUAL DEVICES SHOULD NOT EXCEED 2 FLASHES PER SECOND AND SHOULD NOT BE SLOWER THAN 1 FLASH EVERY SECOND. THE DEVICE SHALL HAVE A PULSING LIGHT SOURCE NOT LESS THAN 15 CANDELLA. VISUAL DEVICES WITHIN 55' FROM EACH OTHER SHALL BE SYNCHRONIZED.
- UNDERGROUND AND EXTERIOR CONDUITS TO HAVE WATER TIGHT FITTINGS AND WIRE TO BE APPROVAL FOR WET LOCATIONS.
- ALL FIRE ALARM WIRING SHALL BE FLP OR FPLP (FIRE POWER LIMITED OR FIRE POWER LIMITED PLENUM) AS REQUIRED FOR APPLICATION. WIRING IN CONDUIT ABOVE GROUND MAY BE THIN OR THIN.
- PER CEC STANDARDS, ALL WIRING IS TO BE PULLED THROUGH EACH JUNCTION BOX AND CONNECTED DIRECTLY TO EACH FIRE DEVICE. DO NOT SPLICE THE WIRE. ALL BOXES TO BE SIZED PER CEC.
- SMOKE DETECTORS SHALL NOT BE ANY CLOSER THAN 1' FROM FIRE SPRINKLERS OR 3' FROM ANY SUPPLY DIFFUSER. IN AREA OF CONSTRUCTION OR POSSIBLE DAMAGE/CONTAMINATION ON NEWLY INSTALLED FIRE ALARM DEVICES SHALL BE COVERED UNTIL THAT AREA IS READY TO BE TURNED OVER TO THE OWNER.
- ALL FIRE ALARM CIRCUITS SHALL BE IN CONDUIT, SURFACE RACEWAY OR OPEN RUN ABOVE CEILING, UNDER FLOORS AND IN WALLS IN A NEAT AND PROTECTED MANNER AS INDICATED ON DESIGN DOCUMENTS. EXPOSED CIRCUITS ARE ONLY PERMITTED WHEN NOTED AS EXPOSED ON DESIGN DOCUMENTS.
- FIRE ALARM PANEL, REMOTES, AND COMPONENTS SHALL BE SECURED TO MOUNTING SURFACES PER MANUFACTURERS SPECIFICATIONS. NO SINGLE DEVICE SHALL EXCEED THE WEIGHT OF 20 LBS. WITHOUT SPECIAL MOUNTING DETAILS.
- A DEDICATED BRANCH CIRCUIT SHALL BE PROVIDED FOR FIRE ALARM EQUIPMENT. THIS CIRCUIT SHALL BE ENERGIZED FROM THE COMMON USE AREA PANEL AND SHALL HAVE NO OTHER OUTLETS. THE BREAKER SHALL HAVE A RED LOCKING DEVICE TO BLOCK THE HANDLE IN THE "ON" POSITION. THE CIRCUIT BREAKER SHALL BE LABELED "FIRE ALARM CIRCUIT CONTROL". CIRCUIT ID TO BE LABELED AT FIRE PANEL/EXTENDERS.
- THE INSTALLING CONTRACTOR SHALL PROVIDE A RECORD OF COMPLETION PER NFPA 72, FIGURE 10.18.2.1.1.
- CONTROL PANELS, REMOTE ANNUNCIATORS SHALL BE INSTALLED WITH THEIR BOTTOMS MOUNTED AT 48"
- THE INSTALLING CONTRACTOR SHALL PROVIDE SYSTEM PROGRAMMING FOR SUPERVISORY MONITORING PER CFC SECTION 901.6.2.
- SUPERVISORY MONITORING SHALL BE TESTED AND VERIFIED AS SENDING CORRECT SIGNALS IN CONJUNCTION WITH FINAL ACCEPTANCE TEST.
- OWNER SHALL BE RESPONSIBLE FOR ESTABLISHING A FIRE SYSTEM MONITORING CONTRACTOR.

## FIRE ALARM PLAN

SCALE: 1/8" = 1' - 0"

### FIRE ALARM SYMBOLS AND SCHEDULE

ITEM	DESCRIPTION	MODEL NUMBER	CSFM NUMBER	MOUNT	BACK BOX
EXISTING FACP (FOR REFERENCE ONLY)	HOCHIKI #FIRENET 4127	7165-0410:0159		+60"	EQUIPMENT CABINET
VOICE EVACUATION PANEL	HOCHIKI #EVAX-50R	6911-0410:0176		+60"	EQUIPMENT CABINET
NAC SIGNAL & VOICE VAC BOOSTER PANEL	WHEELLOCK #SPB 80/4	6911-0785:0157		+60"	EQUIPMENT CABINET
SPEAKER STROBE	HOCHIKI #HSSPKWLP 15cd 30cd 75cd 110cd TEMPORAL CODE 3	7320-0410:0195		+80"	4"SQ X 2 1/2"D
OUTDOOR HORN	HOCHIKI #HWE 24WR #100E	7135-0410:0187 7300-0410:0189		+80"	4"SQ X 2 1/2"D
ADDRESSABLE CEILING SMOKE DETECTOR WITH BASE	HOCHIKI #ALK-V/YBN-NSA-4	7272-0410:0173			4"SQ X 2 1/2"D
ATTIC HEAT DETECTOR 190" TEMP WITH BASE AND MONITOR MODULE	HOCHIKI #DFE 190/HSC-XXXL #RCME-4	7270-0410:0119 7300-0410:0150		ATTIC	4"SQ X 2 1/2"D
FIRE ALARM CABLE POWER LIMITED	WEST PENN AQ SERIES	7161-0859:0101			4"SQ X 2 1/2"D
END OF LINE RESISTOR	N/A	N/A			LAST DEVICE



### NOTES:

- RISER DIAGRAM IS DIAGRAMMATIC. SEE FIRE ALARM FLOOR PLAN AND FIELD VERIFY EXACT ROUTING AS REQUIRED.
- ALL INTERIOR FIRE ALARM CONDUCTORS ARE INSTALLED IN EMT CONDUIT AND CONCEAL ABOVE CEILING OR INSIDE WALL WITH 3/4" C.
- FIRE ALARM CONDUCTOR CANNOT SPLICE INSIDE PULL BOX. CONDUCTOR MUST BE CONTINUE RUN BETWEEN FIRE ALARM DEVICES BACK BOX OR TERMINAL CABINET.

## TYPICAL FIRE ALARM DEVICES MTD DETAIL

N.T.S.

## FIRE ALARM RISER DIAGRAM

N.T.S.

Overship of Documents  
 This document, the ideas and designs incorporated herein, as an instrument of Professional Service is the property of Integrated Designs by SOMAM Inc. and is not to be used, in whole or in part for any other project without written authorization.  
 © COPYRIGHT 2013

Integrated designs by SOMAM, Inc.  
 ARCHITECTURE - ENGINEERING - INTERIOR DESIGN - CONSTRUCTION MANAGEMENT  
 5011 N. Fremont, Suite 130 Fresno, California 93710  
 Phone (559) 438-0881 Fax (559) 438-0887  
 www.integrateddesigns.com

Rev. Date: \_\_\_\_\_  
 Revision Description: \_\_\_\_\_

PROJECT NAME & ADDRESS: **FIRE ALARM PLAN**  
**FREMONT ELEMENTARY SCHOOL**  
**1 RELOCATABLE CLASSROOM**  
 BAKERSFIELD CITY SCHOOL DISTRICT  
 607 TEXAS STREET, BAKERSFIELD, CA

Issue Date: 00/00/17  
 Date: 06/30/17  
 Designer: J. CHONG  
 D.R.: J. CHONG  
 P.C.: \_\_\_\_\_

Agency Approval Stamp:  
 FILE #:  
 IDENTIFICATION STAMP  
 DIV. OF THE STATE ARCHITECT  
 OFFICE OF REGULATION SERVICES  
 03-118270  
 AC ME FLS PHSS ec  
 DATE NOV - 8 2017  
 TRACKING #: DSA TRACKING NO.

Stamp(s): \_\_\_\_\_

Job No.: **5269**  
 Sheet No.: **E-3**  
 Release: \_\_\_\_\_

CONSULTING ENGINEERS  
**JOHN CHONG ENGINEERING**  
 JOHN S. CHONG  
 E 14419  
 Exp. 6/30/2019  
 ELECTRICAL  
 STATE OF CALIFORNIA  
 840 N HELM AVE #109 FRESNO CA 93711  
 (559) 252-2286 • FAX 251-3401  
 jchenginer@aol.com