

PAMP HANDRAL MOTES

- A. ALL PAMP HAMBRAILS SHALL HAVE ROLLHOED OR BEVELED EDGES. CONTRACTOR TO FIELD VERZIFY CONDITION OF (E) HAMDRAILS
- B. ALL PAMP HANDRAILS SHOLL HAVE A 12" MIN. LEVEL EXTENSION.

KEY NOTES

- PROPOSED ACCESSIBLE PATH OF TRAVEL PER THIS APPLICATION. SEE ACCESSIBILITY NOTES, SHEET
- FIELD FOR COMPLIANCE . NEW TACTILE EXIT SIGN PER DETAIL 2/A1.03

EXISTING ACCESSIBLE PATH OF TRAVEL, VERIFY IN

- NEW ROOM IDENTIFICATION AND ISA SIGNAGE, REFER TO DETAILS 3 & 4/A1.03 NEW 20' WIDE FIRE TRUCK ACCESS LANE OVER
- EXISTING AC PAVING, APPROVED BY THE LOCAL NEW TEMPORARY PORTABLE BUILDINGS ON RAISED
- EXISTING LANDSCAPE AREA TO REMAIN. NO WORK

WOOD FOUNDATIONS WITH METAL RAMP SUPPLIED


- 8. EXISTING PLAYBOX TO REMAIN. NO WORK
- 9. EXISTING BUILDING TO REMAIN. NO WORK

BY MANUFACTURER

- 10. EXISTING CONCRETE WALKWAY TO REMAIN. NO
- 11. EXISTING A.C. PAVING TO REMAIN. NO WORK
- 12. NEW RAMP TRANSITION PER PC #04-104169 DETAIL 19/R1.02
- 13. NEW RAMP TRANSITION PER PC #04-100596 DETAIL
- 14. NEW RAMP TRANSITION PER PC #67333 DETAIL
- 13. CONTRACTOR SHALL PROVIDE AND INSTALL A RIGID METAL SCREEN FROM THE BOTTOM OF THE MECHANICAL UNIT TO FINISHED GRADE, PAINT

Ownership of Documents This document, the ideas and designs

incorporated herein, as an instrument of Professional Service is the property of Integrated Designs by SOMAM Inc. and is not to be used, in whole or in part for any other project without written authorization. © COPYRIGHT 2014



GENERAL NOTES

A. DETERIORATION OR EXISTING NON-COMPLIANT CONSTRUCTION:

IF ANY CONDITION IS DISCOVERED WHICH, IF LEFT UNCORRECTED, WOULD MAKE THE BUILDING NON-COMPLIANT WITH THE REQUIREMENTS OF THE EDITION OF THE CBC IN FORCE AT THE TIME OF ORIGINAL CONSTRUCTION, THE CONDITION MUST BE CORRECTED IN ACCORDANCE WITH CURRENT CODE REQUIREMENTS. A C.C.D. OR A SEPARATE SET OF PLANS AND SPECIFICATIONS DETAILING AND SPECIFYING THE REQUIRED REPAIR WORK SHALL BE SUBMITTED TO AND APPROVED BY DSA BEFORE PROCEEDING WITH THE REPAIR WORK.

*PER DSA IR 16-1, SEC. 5.4

CONTRACTOR SHALL ADJUST ALL DOOR CLOSERS TO A MAXIMUM OPENING FORCE OF 5 LBF

	≥ 0
Z	جب 🔾
7	~()
U	
	rn (C)
_	72
	い >
	12
Ш	
75	
U)	7
_	TABLE CLASSROOMS EMENTARY SCHOOL
C)	
\simeq	
-	
√ .	ن
ENLARGED SITE PLAN	OCATABLE CLASSROOMS SEY ELEMENTARY SCHOOL
=	5
4 a .1	AX 10

SERIAL NUMBER SCHEDULE

CLSRM	STKP#	SERIAL#
26	04-104169	57948 / 57949
36	04-100596	35591 / 35592
37	04-100596	35609 / 35610
T4	67333	25670 / 25671

SAFE DISPERSAL

TEMPORARY CLASSROOMS

(4) NEW CLASSROOMS @ 960 S.F. EA. = 3,840 S.F. (2) (E) CLASSROOMS @ 960 S.F. EA.

= 1,920 S.F. TOTAL = 5,760 S.F.

5,760 S.F. / 20 S.F. PER OCCUPANT = 288 OCCUPANTS 288 OCCUPANTS x 5 S.F. / OCCUPANT 1,440 S.F. REQ'D 30' x 48' = 1,440 S.F. PROVIDED

IDENTIFICATION STAMP
DIV OF THE STATE ARCHITECT

Agency Approval Stamp

APPO3 116574 ACAC FLS 65 SS FACE DATE SEP 2 3 2015



5156

LEGEND

INDICATES EXISTING BUILDING TO REMAIN (NO WORK)

INDICATES NEW PORTABLE BUILDING UNDER THIS APPLICATION INDICATES PROPOSED FIRE TRUCK ACCESS OVER A.C. PAVING

HALF-TONE DASHED LINE INDICATES **EXISTING ACCESSIBLE PATH OF TRAVEL**

A1.02

OF TRAVEL, THIS APPLICATION

G:\2015frs\15-5156 Munsey ES Relos\Sheets\5156-A102 ENLARGED SITE PLAN.dwg JOSH FRANCIS

• • • • • • INDICATES PROPOSED ACCESSIBLE PATH